

ISS.	DATE	COMMENTS
1	04/06/14	ORIGINAL



**UNIT IS POSITIONED OUTSIDE ROOM BEING DRIED**

REGENERATION AIR OUT (WET AIR)  
THIS SHOULD BE DUCTED OUTSIDE  
OF BUILDING IF POSSIBLE.  
**DO NOT** DUCT INTO ROOM BEING DRIED

PROCESS AIR IN (AIR REQUIRING DRYING)  
THIS MUST BE DUCTED FROM THE ROOM  
BEING DRIED TO THE DEHUMIDIFIER

REGENERATION AIR IN  
THIS DOES NOT REQUIRE ANY  
DUCTING WHEN UNIT IS OUTSIDE  
THE ROOM BEING DRIED

PROCESS AIR OUT (DRY AIR)  
THIS MUST BE DUCTED INTO THE  
ROOM BEING DRIED

 BISHOP AUCKLAND Co. DURHAM ENGLAND	TITLE <b>DD MID RANGE - DUCTING ARRANGEMENT</b>		
	MATERIAL N/A	DRAWN : <b>W DAGLISH</b>	
3RD ANGLE PROJECTION  DO NOT SCALE IF IN DOUBT ASK	DIMENSIONS IN m.m. TOLERANCES UNLESS OTHERWISE STATED 0. ± 1 0.0 ± 0.25 0.00 ± 0.05 ANGULAR ± 0.5 DEGREE	FINISH N/A	CAD SCALE : <b>1/12</b>
			DRG.NO. <b>1052012</b>